

# CERTIFICATE FI 28582



Our Ref. 275845-4

**Product** Heating cable  
**Type** W\*FP\*  
**Trade mark** **Warmup**  
**Certificate Holder** Warmup PLC  
 702&704 Tudor Estate Abbey Road  
 LONDON NW10 7UW  
 UNITED KINGDOM

**Technical information** Max. 40 W/m, 300/500 V  
 Rated temperature 70°C, Class M2  
 With cold lead, splice and end seal

**Other information** See the Appendix to this Certificate

**The product is certified according to the following standard(s)** IEC 60800:2009 (Ed 3)

**Validity** This certificate is valid until 26 May 2019 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Directive information** The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.

**Date of issue** 26 May 2014

**SGS Fimko Ltd**

**Signature**

Sixten Lökfors  
 Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.